

Australian Standards – Licence – Cautionary Note

Cautionary Note:

1. Constant hot potable water temperatures should not exceed 70°C.
2. Care should be exercised in mixed PP-R/Copper hot potable water recirculation systems where temperatures / pressures may exceed 70°C (permissible working pressure see page 14 of Fusiotherm Pipe System brochure Edition 01/2011) and where copper pipe velocities may exceed established international copper design practice – enquirers should refer to the project's Hydraulic Consultant.
Upstream use of copper pipe in PP-R hot water recirculating systems where the above operational parameters are exceeded should be avoided.
3. The service life of aquatherm PP-R pipe systems could be reduced by using excessive concentration of disinfecting products.