

Emission Test Certificate

Friday, 27th May 2011

Supplier: Aquatherm (Aust) Holdings Pty Ltd (6F/443 West Botany St, Rockdale, NSW, 2216)

Sample Description: Aquatherm Firestop; PP-R Piping, Stop Valve and Brass Connector

Date Tested: May 2011

Test Method: ASTM D5116 "Standard Guide for Small-Scale Environmental Chamber Determinations of Organic Emissions from Indoor Material/Products".

Emission Data:

<p style="text-align: center;">Specification</p> <p style="text-align: center;">Green Building Council of Australia Green Star Office Design V2/V3 IEQ-13</p>	<p style="text-align: center;">Aquatherm Firestop; PP-R Piping, Stop Valve and Brass Connector</p>
<p>Total Volatile Organic Compound emission rate <0.5 mg/m²/hr (24 Hours)</p>	<p>Total Volatile Organic Compound emission rate <0.004 mg/m²/hr (24 Hours)</p>



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

CV110515

V.O.C. DATA SHEET

Volatile Organic Compound Content Data Sheet

1. PRODUCT IDENTIFICATION

TRADE NAME (AS LABELED): **KODAK VERSAMARK FD1007 BLACK INK**

CHEMICAL NAME/CLASS: Aqueous solution of dye.

PRODUCT USE: Ink Jet Printing Ink.

SUPPLIER/MANUFACTURER'S NAME: **EASTMAN KODAK COMPANY**

ADDRESS: 3000 Research Blvd.
Dayton, OH 45420-4099

BUSINESS PHONE: 1-937-259-3000

DATE OF PREPARATION: May 10, 1996

2. PRODUCT ANALYSIS and V.O.C. CONTENT

Property	Value
Product Density @ 25°C	8.49 pounds per gallon
Product Water Content (% by weight)	94.3%
Product Solids Content (% by weight)	5.7%
Volatile Organic Compounds	<0.01 pounds per gallon

Results obtained using procedures defined by 40 CFR, Part 60, Appendix A, Method 24, "Determination of Volatile Matter Content, Water Content, Density, Volume Solids, and Weight Solids of Surface Coatings".